


# DECKENMONTAGE DECKENWANDSCHLAUFE



VKF-Zertifikat

## DATEN

Belastung	7.5kg/Schelle
Schellenabstand	0.8m
Konfigurationsnummer	1.08



# STÜCKLISTE

N°	PRODUKTEBEZEICHNUNG	ELDAS N°	LANZ N°	ELDAS N°	LANZ N°	ELDAS N°	LANZ N°
<b>DWS DECKENWANDSCHLAUFE</b>		SVZ/GVZ		FVZ		A4	
2	54x70	-	334 105	-	-	120 006 726	334 005
2	68x110	-	334 110	-	-	120 007 126	334 010
2	105x140	120 006 926	334 015	-	-	-	-



## ZUBEHÖR

1	Bolzenanker FAZ II 6/10 M6x65	127 092 006	339 010	-	-	127 092 026	369 010
1	Betonschraube FBS II 6x60	160 006 006	339 039	-	-	-	-



	Aufkleber Funktionserhalt	127 099 599	302 140	-	-	-	-
--	---------------------------	-------------	---------	---	---	---	---



## GEPRÜFTE KABELBAUARTEN

(N)HXH FE180 E90	geprüft: <b>E90</b>
(N)HXCH FE180 E90	geprüft: <b>E90</b>
(N)HXH FE180 E30-E60	geprüft: <b>E30</b>
(N)HXCH FE180 E30-E60	geprüft: <b>E30</b>

JE-H(St)H FE180 E30-E90	geprüft: <b>E60</b>
JE-H(St)HRH FE180 E30-E90	geprüft: <b>E60</b>